



Chhatrapati Sambhajanagar. Municipal Corporation

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/AMC/FIRE/281/2026

Date 7/02/2026

To,
Bhagwan Shikshan Prasarak Mandal,
Shri. Bhagwan Homoeopathic Medical College & Hospital,
Dr. Y.S. Khedkar Marg, S.No. 05/P, N-6,
Cidco. Chhatrapati Sambhajanagar.

Sub:- Final Fire Noc is issued to the Shri. Bhagwan Homoeopathic Medical College & Hospital,
Dr. Y.S. Khedkar Marg, S.No. 05/P, N-6, Cidco. Chhatrapati Sambhajanagar.

Ref:- 1) Your Letter date 23/11/2012 2) Provisional Noc on date 24/11/2012
3) Your Letter date 03/02/2026 4) CFO Inspection on date 04/02/2026

With Reference to the above subject Final Fire Noc is issued to the Shri. Bhagwan Homoeopathic Medical College & Hospital, Dr. Y.S. Khedkar Marg, S.No. 05/P, N-6, Cidco. Chhatrapati Sambhajanagar. Plot area 20388.20 Sq.mtr.

Owner has paid Final Fire Noc Rs. 10,000/- in Fire brigade Receipt No. 13471 date 07/02/2026.

S.No	Building	Height	Building	Floor	Area of Plot	Builtup Area	Noc Fees	Total Rs
1	Shri. Bhagwan Homoeopathic Medical College & Hospital	11.65 mtr	1	G+3	20388.20 Sq.mtr	5616.15 Sq.mtr	10000	10000
							10000	10000

Following Fire prevention and Fire protection & Fire Fighting measures subject to the Shri. Bhagwan Homoeopathic Medical College & Hospital is provided.

1. Open space all around the building is provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Underground Water tank 50000 Ltr & Main Fire Pump-2280 LPM-01 No, Jockey Pump-180 LPM-01 Nos of Suitable capacity for building is Provided.
3. 01 Nos. Fire service inlet 2 way incoming is provided.
4. 04 Nos. Hydrant points all around the building with fire Hose Pipe-24 Nos/ Branch-12 Nos is provided.
5. 03 Nos. Wet Riser having outlet on all floors with Hose Pipe-24 / Branch-12 shall be Provided.
6. 12 Nos Hose Reel of 100 feet on all outlets is provided.
7. Fire Extinguisher of / ABC-06 Kg-50 Nos of Suitable Capacity / quantity is provided.
8. Sprinklar System -181 Nos, Smoke Detector System -129 Nos. Manual Call Point -03 Nos, Hooter -03 Nos is Provided.
9. This Certificate shall be treated valid for a period of one year from, the date of issue up to Final Fire Noc
- 11 Fire Noc must be Renewaled on each year.

As per BPMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject Final Fire Noc is issued to the Bhagwan Shikshan Prasarak Mandal, Shri. Bhagwan Homoeopathic Medical College & Hospital, Dr. Y.S. Khedkar Marg, S.No. 05/P, N-6, Cidco. Chhatrapati Sambhajanagar.

Chief Fire Officer
Fire Brigade, Municipal Corporation
Chhatrapati Sambhajanagar.

Principal
Shri Bhagwan Homoeopathic
Medical College, Dr. Y. S. Khedkar Marg
N-6, Cidco, Aurangabad.

Copy to:- C S T.P, Chhatrapati Sanbhajanagar.